# 2013 Annual Drinking Water Quality Report Union County Public Works

Water System Number: 01-90-413

We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is a snapshot of last year's water quality. Included are details about your sources of water, what it contains, and how it compares to standards set by regulatory agencies. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water and to providing you with this information because informed customers are our best allies. If you have any questions about this report or concerning your water, please contact Junior Honeycutt at (704) 289-7044. We want our valued customers to be informed about their water utility. If you want to learn more, please visit our website at www.co.union.nc.us.

#### What EPA Wants You to Know

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. [Name of Utility] is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <a href="http://www.epa.gov/safewater/lead">http://www.epa.gov/safewater/lead</a>.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

## When You Turn on Your Tap, Consider the Source

The water that is used by Union County Public Works comes from two surface sources, the Catawba River located in Lancaster County, S.C. and the Pee Dee River located in eastern Anson County.

#### Source Water Assessment Program (SWAP) Results

The North Carolina Department of Environment and Natural Resources (DENR), Public Water Supply (PWS) Section, Source Water Assessment Program (SWAP) conducted assessments for all drinking water sources across North Carolina. The purpose of the assessments was to determine the susceptibility of each drinking water source (well or surface water intake) to Potential Contaminant Sources (PCSs). The results of the assessment are available in SWAP Assessment Reports that include maps, background information and a relative susceptibility rating of Higher, Moderate or Lower.

The relative susceptibility rating of each source for Union County Public Works was determined by combining the contaminant rating (number and location of PCSs within the assessment area) and the inherent vulnerability rating (i.e., characteristics or existing conditions of the well or watershed and its delineated assessment area). The assessment findings are summarized in the table below:

#### Susceptibility of Sources to Potential Contaminant Sources (PCSs)

Source Name	Susceptibility Rating	SWAP Report Date
Catawba River	Moderate	April 2003
		(Reviewed Annually)
Pee Dee River	Moderate	March 2010

The complete SWAP Assessment report for the Anson County Water Plant may be viewed on the Web at: <a href="https://www.ncwater.org/pws/swap">www.ncwater.org/pws/swap</a>. Note that because SWAP results and reports are periodically updated by the PWS Section, the results available on this web site may differ from the results that were available at the time this CCR was prepared. If you are unable to access your SWAP report on the web, you may mail a written request for a printed copy to: Source Water Assessment Program – Report Request, 1634 Mail Service Center, Raleigh, NC 27699-1634, or email requests to swap@ncdenr.gov. Please indicate your system name, number, and provide your name, mailing address and phone number. If you have any questions about the SWAP report please contact the Source Water Assessment staff by phone at 919-707-9098.

The complete SWAP Assessment for the Catawba River Water Treatment Plant can be obtained by contacting the Bureau of Water in Columbia, South Carolina at (803)898-4300 or on the web at <a href="http://www.scdehec.net/water">http://www.scdehec.net/water</a>.

It is important to understand that a susceptibility rating of "higher" <u>does not</u> imply poor water quality, only the system's potential to become contaminated by PCSs in the assessment area.

#### **Water Quality Data Tables of Detected Contaminants**

We routinely monitor for over 150 contaminants in your drinking water according to Federal and State laws. The table below lists all the drinking water contaminants that we <u>detected</u> in the last round of sampling for the particular contaminant group. The presence of contaminants does <u>not</u> necessarily indicate that water poses a health risk. **Unless otherwise noted, the data presented in this table is from testing done January 1 through December 31, 2012.** The EPA and the State allow us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulations are warranted.

#### **Important Drinking Water Definitions:**

*Not-Applicable* (*N/A*) – Information not applicable/not required for that particular water system or for that particular rule.

**Parts per million (ppm) or Milligrams per liter (mg/L)** - One part per million corresponds to one minute in two years or a single penny in \$10,000.

*Parts per billion (ppb) or Micrograms per liter (ug/L)* - One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

**Nephelometric Turbidity Unit (NTU)** - Nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

**Action Level (AL)** - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A required process intended to reduce the level of a contaminant in drinking water.

*Maximum Residual Disinfection Level Goal (MRDLG)* – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

*Maximum Residual Disinfection Level (MRDL)* – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

*Maximum Contaminant Level (MCL)* - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal (MCLG)* - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

#### **Tables of Detected Contaminants**

Turbidity\*

I al blaity				
Contaminant (units)	Treatment Technique (TT) Violation Y/N	Your Water	Treatment Technique (TT) Violation if:	Likely Source of Contamination
Turbidity (NTU) - Highest single turbidity measurement Anson Catawba	N N	0.46 NTU 0.09 NTU	Turbidity > 1 NTU	
Turbidity (NTU) - Lowest monthly percentage (%) of samples meeting turbidity limits Anson Catawba	N N	99% 100%	Less than 95% of monthly turbidity measurements are ≤ 0.3 NTU	Soil runoff

<sup>\*</sup> Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system. The turbidity rule requires that 95% or more of the monthly samples must be less than or equal to 0.3 NTU.

**Inorganic Contaminants** 

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range Low High	MCLG	MCL	Likely Source of Contamination
Fluoride (ppm) Anson Catawba	2012 2012	N N	0.84 0.90	0.16-1.33 0.59-1.0	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories

#### **Nitrate/Nitrite Contaminants**

Contaminant (units)	MCL Violation Y/N	Your Water	Range Low High	MCLG	MCL	Likely Source of Contamination
Nitrate (as Nitrogen) (ppm) Catawba	N	1.7	1.7-1.7	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

**Unregulated Inorganic Contaminants** 

Contaminant (units)	Sample	Your	Range	Secondary
	Date	Water	Low High	MCL
Sulfate (ppm) Anson	2012	19.9	19.9-19.9	250

Synthetic Organic Chemical (SOC) Contaminants Including Pesticides and Herbicides

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range Low High	MCLG	MCL	Likely Source of Contamination
2,4-D (ppb) Catawba	2012	N	0.36	0.36-0.36	70	70	Runoff from herbicide used on row crops

**Unregulated VOC Contaminants** 

Contaminant (units)	Sample Date	Your Water	Range Low High
Chloroform (ppb)			
Anson	2012	31.3	26.6-31.3
Bromodichloromethane (ppb)			
Anson	2012	5.8	5.3-5.8

**Lead and Copper Contaminants** 

zena ana copper comun						
Contaminant (units)	Sample Date	Your Water	# of sites found above the AL	MCLG	AL	Likely Source of Contamination
Copper (ppm)						
(90 <sup>th</sup> percentile)				1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
Anson	2012	0.157	0/32	1.5	AL=1.5	
Union County	2011	0.15	0/50			
Lead (ppb)						Corrosion of household plumbing
(90 <sup>th</sup> percentile)				0	AL=15	systems, erosion of natural deposits
Union County	2011	0.003	2/50			systems, crosion of natural deposits

**Total Organic Carbon (TOC)** 

Total Olganic Car	( )						
Contaminant (units)	TT Violation Y/N	Your Water (RAA Removal Ratio)	Range Monthly Removal Ratio Low - High	MCLG	TT	Likely Source of Contamination	Compliance Method (Step 1 or ACC#)
Total Organic Carbon (removal ratio) (TOC)-TREATED Anson Catawba	N N	1.25 1.0	1.01-1.51 1.0-1.0	N/A	TT	Naturally present in the environment	SUVA Method

## **Disinfectants and Disinfection Byproducts Contaminants**

Contaminant (units)	MCL/MR DL Violation Y/N	Your Water RAA (Stage 1)	Range Low High	MCLG	MCL	Likely Source of Contamination
TTHM (ppb) [Total Trihalomethanes] Union County	N	25	10- 45	N/A	80	By-product of drinking water chlorination
HAA5 (ppb) [Total Haloacetic Acids] Union County	N	27	14- 46	N/A	60	By-product of drinking water disinfection
Chlorite (ppm) Catawba	N	0.34	0.09- 0.57	0.8	1.0	By-product of drinking water chlorination
Chlorine dioxide (ppb) Catawba	N	3.0	0.0- 9.0	MRDLG = 800	MRDL = 800	Water additive used to control microbes
Chloramines (ppm) Union County	N	2.27	1.01- 3.25	MRDLG = 4	MRDL = 4	Water additive used to control microbes
Chlorine (ppm) Union County	N	2.25	0.10- 3.90	MRDLG = 4	MRDL = 4	Water additive used to control microbes

The PWS Section requires monitoring for other misc. contaminants, some for which the EPA has set national secondary drinking water standards (SMCLs) because they may cause cosmetic effects or aesthetic effects (such as taste, odor, and/or color) in drinking water. The contaminants with SMCLs normally do not have any health effects and normally do not affect the safety of your water.

#### **Other Miscellaneous Water Characteristics Contaminants**

Contaminant (units)	Sample Date	Your Water	Range Low/High	SMCL
Iron (ppm) Anson	2012	0.03	0.01-0.16	0.3 mg/L
Manganese (ppm) Anson	2012	0.008	0.001-0.03	0.05 mg/L
Sodium (ppm) Anson	2012	9.92	9.92-9.92	N/A
Sulfate (ppm) Anson	2012	19.9	19.9-19.9	250 mg/L
pH Anson	2012	7.3	6.7-10.4	6.5 to 8.5

\*\*NOTE (Spanish) Para más información o explicación sobre la cualidad de agua por favor llame (704) 296-4229 para español.

# **Consumer Confidence Report Certification Form**

water System Name:		
Water System No.:	Report Year:	Population Served:
141 and 142 requiring the developmentave been executed. Further, the CW consistent with the compliance monitor	nt of, distribution of, and notific S certifies the information conta oring data previously submitted is report is being used to meet T, the CWS certifies that public n	to the primacy agency by their NC ier 3 Public Notification requirements, otification has been provided to its
Certified by: Name:	Ti	itle:
Signature:	Pł	none #:
Delivery Achieved Date:	Da	ate Reported to State:
☐ The CCR includes text which provi	des mandated Public Notice for ε	a monitoring violation (check box, if yes)
Notification Method  □ Notification of CCR URL  Notification Method  □ Direct email delivery of CCR  Notification Method  □ Newspaper (attach copy) Windle Method	URL:(i.e. on bedded? or embedded? (interpretation of embedded)	(i.e. US Mail, door hanger)
,	_	Extra efforts included the following
$\Box$ posting the CCR on the	e Internet at URL:	
☐ mailing the CCR to po	stal patrons within the service ar	rea
<del>-</del>	ility of the CCR in news media	
<ul><li>publication of the CCF</li></ul>	R in local newspaper (attach copy	y)
• •	blic places such as: (attach list i	
	pies to single bill addresses serv , and large private employers	ing several persons such as:
<ul> <li>delivery to community</li> </ul>	organizations such as: (attach li	ist if needed)

#### INSTRUCTIONS

#### Submittal of your CCR and Certification Form to the Public Water Supply Section

You may now submit your CCR and Certification form by <u>either</u> method described below. Follow the directions to ensure efficient tracking and receipt of your submittal and expedited review of report data by the Public Water Supply (PWS) Section for compliance with state and federal regulations.

#### By Email:

- Provide your Water System Name and Water System Number (e.g. Water System Name NC0101010) in the subject line of the email.
- If your CCR is displayed on a Web page, provide the direct URL for the report in the body of your email, and attach your completed Certification form to the email. (Note: Water systems <u>without</u> a web page/direct URL must attach <u>both</u> the CCR and the Certification form to the email as either a Word or PDF document.)
- Email your documents to: <a href="mailto:PWSS.CCR@ncdenr.gov">PWSS.CCR@ncdenr.gov</a> (use 'Return Receipt Requested' to verify PWS Section's receipt.)
- **By Postal Mail:** Mail your CCR and Certification form to: Public Water Supply Section, 1634 Mail Service Center, Raleigh, NC 27699-1634, Attn: CCR Rule Manager.

#### **CCR Customer Direct Delivery Requirements (Based on Population)**

- > Systems serving 100,000 or more persons must post the CCR on a publicly-accessible Internet site using a direct URL.
- > Systems serving 10,000 or more persons must distribute the CCR by mail or direct delivery.
- > Systems serving less than 10,000 persons but more than 500 persons must either: (1) distribute the CCR by mail or direct delivery <u>OR</u> (2) notify their customers that the CCR is not being mailed, but it will be in what newspaper(s) and when (attach copy of notice). The complete CCR should be printed in the local newspaper, and a copy of the CCR must be made available upon request. (The 2<sup>nd</sup> option is not acceptable if using the CCR for Tier 3 Public Notification!)
- > Systems serving 500 or fewer persons must either: (1) distribute the CCR by mail or direct delivery OR (2) notify their customers that the CCR is not being mailed, and a copy of the CCR must be made available upon request. (The 2<sup>nd</sup> option is not acceptable if using the CCR for Tier 3 Public Notification!)

**CCR Direct Delivery Methods for Bill-Paying Customers** 

	METHOD DESCRIPTION
	(Click link: EPA-CCR Rule Delivery Options Memo January 3, 2013.
CCR DELIVERY METHOD	for referenced Appendix Figures below.)
Mail – paper copy	CWS mails a paper copy of the CCR to each bill-paying customer.
Mail – notification that CCR is available on web site via a direct URL	CWS mails to each bill-paying customer a notification that the CCR is available and provides a direct URL to the CCR on a publicly available site on the Internet where it can be viewed. A URL that navigates to a web page that requires a customer to search for the CCR or enter other information does not meet the "directly deliver" requirement. The mail method for the notification may be, but is not limited to, a water bill insert, statement on the water bill or community newsletter. See Figure 1 in the Appendix.
Email – direct URL to CCR	CWS emails to each bill-paying customer a notification that the CCR is available and provides a direct URL to the CCR on a publicly available site on the Internet. A URL that navigates to a web page that requires a customer to search for the CCR or enter other information does not meet the "directly deliver" requirement. This method may only be used for customers when a CWS has a valid email address to deliver the CCR electronically. See Figure 2 in the Appendix.
Email – CCR sent as an attachment to email	CWS emails the CCR as an electronic file email attachment [e.g., portable document format (PDF)]. This method may only be used for customers when a CWS has a valid email address to deliver the CCR electronically. See Figure 3 in the Appendix.
Email – CCR sent as an embedded image in an email	CWS emails the CCR text and tables inserted into the body of an email (not as an attachment.) This method may only be used for customers when a CWS has a valid email address to deliver the CCR electronically. See Figure 4 in the Appendix.
Additional electronic delivery that meets "otherwise directly deliver" requirement	CWS delivers CCR through a method that "otherwise directly delivers" to each bill-paying customer and in coordination with the primacy agency. This category is intended to encompass methods or technologies not included above. CWSs and primacy agencies considering new methods or technologies should consult with the EPA to ensure it meets the intent of "otherwise directly deliver."