

**Union County
North Carolina**



**Crooked Creek WRF Electrical Systems Improvements – IFB No.
2021-027 Re-Bid**

ADDENDUM NO. 1

ISSUE DATE: December 29, 2020

Bidders on this project are hereby notified that this Addendum shall be attached to and made a part of the above named Contract Documents.

The following items add to, modify, and clarify the Contract Documents and shall have the full force and effect of the original Documents. Bids shall conform to those items and the cost change, if any, of these items shall be included in this Bid Price. This Addendum shall be acknowledged by the Bidder on Page 1 of the Bid Form, C-410.

THIS PAGE INTENTIONALLY LEFT BLANK

IN THE SPECIFICATIONS

C-410 Bid Form

- 1. New Bid Form attached to Addendum No. 1 which includes:
 - a. Revised Article 5
 - b. Provides Attachment A List of Subcontractors/Suppliers
 - c. Provides Attachment B Bidders Qualification Statement

003143 Permit Application

- 1. Union County Permitting Plan Review Approval document is to be attached to the end of the section.

264113 Lightning Protection for Structures

- 1. Robbins Lighting, Inc (Maryville, MO) is approved as a manufacturer under section 2.1.A


406100 Process Control and Enterprise Management System General

- 1. ADD new section 1.8.E.2: "Lord and Company, Inc. – Contact Pierre Wooten; Phone: 803-984-1228"

IN THE DRAWINGS


E-6

- 1. ADD note 8: "Provide two (2) bollards at the new generator. Location to be field determined by ENGINEER." Bollard detail provided adjacent.



E-11

- 1. New Sheet E-11 issued to show calculated load for MCC-1 and MCC-900.



ATTACHMENTS

- 1. C-410 Bid Form
- 2. Union County Permitting Plan Approval
- 3. Sheet E-11

END OF ADDENDUM NO. 1