



**Request for Proposals No. 2022-065**

**Fire Alarm Testing and Related Services**

.....

**ADDENDUM No. 2**

**ISSUE DATE: May 6, 2022**

Responding Offerors on this project are hereby notified that this Addendum shall be made a part of the above-named RFP document.

The following items add to, modify, and/or clarify the RFP documents and shall have the full force and effect of the original Documents. This Addendum shall be acknowledged by the Offeror in the RFP document.

**Notice**

The due date has been extended to Tuesday, May 24, 2022 at 11:00 AM EDT.

**A.) Add/Delete/Remove**

1. **DELETE**, All references to due date: ~~May 10, 2022 at 11:00 AM EDT~~

**Replace with the following due date: May 24, 2022 at 11:00 AM EDT**

2. **DELETE**, Question #18 from Addendum No.1 in its entirety.

**Question:** ~~Does Union County currently have wireless dialers?~~

**Answer:** No

**B.) Questions & Answers**

1. **Question:** Does Union County currently have wireless dialers?

**Answer:** Yes.

2. **Question:** According to the reports, the 4G Honeywell communicators will not work past the end of 2022. Will the communicators be replaced or upgraded soon?

**Answer:** The current vendor plans to upgrade these prior to the new contract being awarded.

\*\*\*\*\*

**END OF ADDENDUM No.2**