



Invitation for Bid No. 2022-040

Hwy 75 Pump Control Valve and Actuator Replacement

.....

ADDENDUM No. 1

ISSUE DATE: May 13, 2022

Responding Offerors on this project are hereby notified that this Addendum shall be made a part of the above named IFB document.

The following items add to, modify, and/or clarify the IFB documents and shall have the full force and effect of the original Documents. This Addendum shall be acknowledged by the Offeror in the IFB document.

Add/Delete Section

Add: A Non-Mandatory Pre-Bid Conference and Site Visit will be held at 10:30 AM EDT on Wednesday, May 18, 2022 at 4917 Waxhaw Hwy. Monroe, NC 28110. Attendance is encouraged but not required.

End of Add/Delete Section

Question/Answer Section

1. What electrical voltage and is the operator single phase or three phase?

Answer: Single phase 120v.

2. Please confirm Union Co. operations staff will provide suitable isolation of the system (fluid and electrical) on either side of the valve and power isolation to the operator for removal and installation by the Contractor.

Answer: Yes.

3. Will a site walk be available to see the installation conditions and location? If so, what time and date?

Answer: See Add/Delete Section.

4. Is 316 SS hardware required or is standard hardware acceptable?

Answer: Standard hardware is acceptable.

End of Question/Answer Section

End of Addendum No. 1