



Invitation for Bid No. 2022-043

**12 Mile WRF Grit Facility Odor Control Media
Replacement**

ADDENDUM No. 2

ISSUE DATE: June 8, 2022

Responding Bidders on this project are hereby notified that this Addendum shall be made a part of the above named IFB document.

The following items add to, modify, and/or clarify the IFB documents and shall have the full force and effect of the original Documents. This Addendum shall be acknowledged by the Offeror in the IFB document.

A) Questions & Answers Section

1) Question: Please let me know if you have an idea what the H2S loadings are.

Answer: We do not know the H2S loadings at the plant.

2) Question: Do you have a specification for the carbon you want in this odor control system.

Answer: The Carbon should last a minimum of five (5) years.

3) Question: This material might be considered a hazardous waste with the components it is taking out. Can you let me know if that is the case?

Answer: It is unknown if the media that is currently in the vessel is hazardous. With the TCLP results provided in the IFB, interested vendors should be able to determine the toxicity of the current media.

4) Question: On the Price form page under time of completion: bidder needs to specify the warranty. Will that be for service or media?

Answer: The warranty is for the media.

END OF ADDENDUM No. 2