



Invitation for Bid No. 2023-002

**Union County Public Schools Admin Building Generator
Replacement**

.....

ADDENDUM No. 2

ISSUE DATE: February 21, 2023

Responding Bidders on this project are hereby notified that this Addendum shall be made a part of the above named IFB document.

The following items add to, modify, and/or clarify the IFB documents and shall have the full force and effect of the original Documents. This Addendum shall be acknowledged by the Offeror in the IFB document.

A) Questions & Answers

1) **Question:** Who is Natural Gas provider?

Answer: City of Monroe.

2) **Question:** New concrete over existing?

Answer: Existing slab/floor shall be removed as required for new slab.

3) **Question:** Remove side louver to access for concrete and large equipment in and out?

Answer: Contractor to verify if this is an option.

4) **Question:** Size of door opening to equipment room and to building entry?

Answer: Contractor to verify

5) **Question:** Reuse/tap into existing exhaust piping or new all the way out of building?

Answer: all work shall be new unless otherwise noted.

6) **Question:** What is the size and voltage of the generator being replaced?

Answer: 30kW, 120/240V.

END OF ADDENDUM No.2