



ANALYTICAL REPORT

PREPARED FOR

Attn: Justin Huntley
Union County Water
500 N Main St.
Monroe, North Carolina 28112

Generated 7/11/2023 9:44:35 PM

JOB DESCRIPTION

PFAS - 533

JOB NUMBER

810-65927-1

Eurofins Eaton Analytical South Bend

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and will meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Eaton Analytical, LLC Project Manager.

Authorization



Generated
7/11/2023 9:44:35 PM

Authorized for release by
Joe Mattheis, Project Manager I
Joe.Mattheis@et.eurofinsus.com
(574)233-4777



Table of Contents

Cover Page	1
Table of Contents	3
Definitions/Glossary	4
Case Narrative	5
Detection Summary	6
Client Sample Results	7
Isotope Dilution Summary	11
QC Sample Results	12
QC Association Summary	15
Lab Chronicle	16
Certification Summary	17
Method Summary	18
Sample Summary	19
Chain of Custody	20
Receipt Checklists	22

Definitions/Glossary

Client: Union County Water
Project/Site: PFAS - 533

Job ID: 810-65927-1

Qualifiers

LCMS

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
α	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: Union County Water
Project/Site: PFAS - 533

Job ID: 810-65927-1

Job ID: 810-65927-1

Laboratory: Eurofins Eaton Analytical South Bend

Narrative

Job Narrative
810-65927-1

Receipt

The samples were received on 6/12/2023 8:45 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 22.2°C

Receipt Exceptions

The following samples were received at the laboratory outside the required temperature criteria: T07-Hwy 74 E BPS (810-65927-1), NOR-Norwood WTP (810-65927-2) and J18-Rehobeth ARV (810-65927-3). This does not meet regulatory requirements. The client was contacted regarding this issue, and the laboratory was instructed to <CHOOSE_ONE> proceed with/cancel analysis.

PFAS

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15

Detection Summary

Client: Union County Water
Project/Site: PFAS - 533

Job ID: 810-65927-1

Client Sample ID: T07-Hwy 74 E BPS

Lab Sample ID: 810-65927-1

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Perfluorobutanoic acid (PFBA)	2.8		1.9		ng/L	1		533	Total/NA
Perfluoropentanoic acid (PFPeA)	3.8		1.9		ng/L	1		533	Total/NA
Perfluorohexanoic acid (PFHxA)	3.8		1.9		ng/L	1		533	Total/NA
Perfluorooctanoic acid (PFOA)	3.6		1.9		ng/L	1		533	Total/NA
Perfluorobutanesulfonic acid (PFBS)	2.3		1.9		ng/L	1		533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	4.7		1.9		ng/L	1		533	Total/NA

Client Sample ID: NOR-Norwood WTP

Lab Sample ID: 810-65927-2

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Perfluorobutanoic acid (PFBA)	2.7		1.9		ng/L	1		533	Total/NA
Perfluoropentanoic acid (PFPeA)	3.3		1.9		ng/L	1		533	Total/NA
Perfluorohexanoic acid (PFHxA)	3.3		1.9		ng/L	1		533	Total/NA
Perfluorooctanoic acid (PFOA)	3.3		1.9		ng/L	1		533	Total/NA
Perfluorobutanesulfonic acid (PFBS)	2.1		1.9		ng/L	1		533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	4.3		1.9		ng/L	1		533	Total/NA

Client Sample ID: J18-Rehobeth ARV

Lab Sample ID: 810-65927-3

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Perfluorobutanoic acid (PFBA)	3.6		1.9		ng/L	1		533	Total/NA
Perfluoropentanoic acid (PFPeA)	7.5		1.9		ng/L	1		533	Total/NA
Perfluorohexanoic acid (PFHxA)	7.4		1.9		ng/L	1		533	Total/NA
Perfluoroheptanoic acid (PFHpA)	2.6		1.9		ng/L	1		533	Total/NA
Perfluorooctanoic acid (PFOA)	4.2		1.9		ng/L	1		533	Total/NA
Perfluorobutanesulfonic acid (PFBS)	2.3		1.9		ng/L	1		533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	2.0		1.9		ng/L	1		533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	3.0		1.9		ng/L	1		533	Total/NA

This Detection Summary does not include radiochemical test results.

Eurofins Eaton Analytical South Bend

Client Sample Results

Client: Union County Water
Project/Site: PFAS - 533

Job ID: 810-65927-1

Client Sample ID: T07-Hwy 74 E BPS

Lab Sample ID: 810-65927-1

Date Collected: 06/09/23 08:25

Matrix: Drinking Water

Date Received: 06/12/23 08:45

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorobutanoic acid (PFBA)	2.8		1.9		ng/L		06/20/23 07:25	06/22/23 00:01	1
Perfluoropentanoic acid (PFPeA)	3.8		1.9		ng/L		06/20/23 07:25	06/22/23 00:01	1
Perfluorohexanoic acid (PFHxA)	3.8		1.9		ng/L		06/20/23 07:25	06/22/23 00:01	1
Perfluoroheptanoic acid (PFHpA)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:01	1
Perfluorooctanoic acid (PFOA)	3.6		1.9		ng/L		06/20/23 07:25	06/22/23 00:01	1
Perfluorononanoic acid (PFNA)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:01	1
Perfluorodecanoic acid (PFDA)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:01	1
Perfluoroundecanoic acid (PFUnA)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:01	1
Perfluorododecanoic acid (PFDoA)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:01	1
Perfluorobutanesulfonic acid (PFBS)	2.3		1.9		ng/L		06/20/23 07:25	06/22/23 00:01	1
Perfluoropentanesulfonic acid (PFPeS)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:01	1
Perfluorohexanesulfonic acid (PFHxS)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:01	1
Perfluoroheptanesulfonic acid (PFHpS)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:01	1
Perfluorooctanesulfonic acid (PFOS)	4.7		1.9		ng/L		06/20/23 07:25	06/22/23 00:01	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:01	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:01	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:01	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:01	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:01	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:01	1
9-Chlorohexadecafluoro-3-oxanonan e-1-sulfonic acid	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:01	1
11-Chloroeicosafluoro-3-oxaundecan e-1-sulfonic acid	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:01	1
Perfluoro(4-methoxybutanoic acid)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:01	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:01	1
Perfluoro-3,6-dioxaheptanoic acid	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:01	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C4 PFBA	90		50 - 200	06/20/23 07:25	06/22/23 00:01	1
13C5 PFPeA	132		50 - 200	06/20/23 07:25	06/22/23 00:01	1
13C5 PFHxA	87		50 - 200	06/20/23 07:25	06/22/23 00:01	1
13C4 PFHpA	90		50 - 200	06/20/23 07:25	06/22/23 00:01	1
13C8 PFOA	87		50 - 200	06/20/23 07:25	06/22/23 00:01	1
13C9 PFNA	100		50 - 200	06/20/23 07:25	06/22/23 00:01	1
13C6 PFDA	94		50 - 200	06/20/23 07:25	06/22/23 00:01	1
13C7 PFUnA	94		50 - 200	06/20/23 07:25	06/22/23 00:01	1
13C2 PFDoA	96		50 - 200	06/20/23 07:25	06/22/23 00:01	1
13C3 HFPO-DA	89		50 - 200	06/20/23 07:25	06/22/23 00:01	1
13C3 PFBS	90		50 - 200	06/20/23 07:25	06/22/23 00:01	1
13C8 PFOS	94		50 - 200	06/20/23 07:25	06/22/23 00:01	1
13C2-4:2-FTS	84		50 - 200	06/20/23 07:25	06/22/23 00:01	1

Eurofins Eaton Analytical South Bend

Client Sample Results

Client: Union County Water
Project/Site: PFAS - 533

Job ID: 810-65927-1

Client Sample ID: T07-Hwy 74 E BPS

Lab Sample ID: 810-65927-1

Date Collected: 06/09/23 08:25

Matrix: Drinking Water

Date Received: 06/12/23 08:45

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2-6:2-FTS	81		50 - 200	06/20/23 07:25	06/22/23 00:01	1
13C2-8:2-FTS	101		50 - 200	06/20/23 07:25	06/22/23 00:01	1
13C3 PFHxS	95		50 - 200	06/20/23 07:25	06/22/23 00:01	1

Client Sample ID: NOR-Norwood WTP

Lab Sample ID: 810-65927-2

Date Collected: 06/09/23 09:21

Matrix: Drinking Water

Date Received: 06/12/23 08:45

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorobutanoic acid (PFBA)	2.7		1.9		ng/L		06/20/23 07:25	06/22/23 00:13	1
Perfluoropentanoic acid (PFPeA)	3.3		1.9		ng/L		06/20/23 07:25	06/22/23 00:13	1
Perfluorohexanoic acid (PFHxA)	3.3		1.9		ng/L		06/20/23 07:25	06/22/23 00:13	1
Perfluoroheptanoic acid (PFHpA)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:13	1
Perfluorooctanoic acid (PFOA)	3.3		1.9		ng/L		06/20/23 07:25	06/22/23 00:13	1
Perfluorononanoic acid (PFNA)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:13	1
Perfluorodecanoic acid (PFDA)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:13	1
Perfluoroundecanoic acid (PFUnA)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:13	1
Perfluorododecanoic acid (PFDoA)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:13	1
Perfluorobutanesulfonic acid (PFBS)	2.1		1.9		ng/L		06/20/23 07:25	06/22/23 00:13	1
Perfluoropentanesulfonic acid (PFPeS)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:13	1
Perfluorohexanesulfonic acid (PFHxS)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:13	1
Perfluoroheptanesulfonic acid (PFHpS)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:13	1
Perfluorooctanesulfonic acid (PFOS)	4.3		1.9		ng/L		06/20/23 07:25	06/22/23 00:13	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:13	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:13	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:13	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:13	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:13	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:13	1
9-Chlorohexadecafluoro-3-oxanonan e-1-sulfonic acid	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:13	1
11-Chloroeicosafluoro-3-oxaundecan e-1-sulfonic acid	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:13	1
Perfluoro(4-methoxybutanoic acid)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:13	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:13	1
Perfluoro-3,6-dioxaheptanoic acid	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:13	1
Isotope Dilution	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
13C4 PFBA	84		50 - 200				06/20/23 07:25	06/22/23 00:13	1
13C5 PFPeA	121		50 - 200				06/20/23 07:25	06/22/23 00:13	1
13C5 PFHxA	79		50 - 200				06/20/23 07:25	06/22/23 00:13	1
13C4 PFHpA	82		50 - 200				06/20/23 07:25	06/22/23 00:13	1

Eurofins Eaton Analytical South Bend

Client Sample Results

Client: Union County Water
Project/Site: PFAS - 533

Job ID: 810-65927-1

Client Sample ID: NOR-Norwood WTP

Lab Sample ID: 810-65927-2

Date Collected: 06/09/23 09:21

Matrix: Drinking Water

Date Received: 06/12/23 08:45

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C8 PFOA	80		50 - 200	06/20/23 07:25	06/22/23 00:13	1
13C9 PFNA	92		50 - 200	06/20/23 07:25	06/22/23 00:13	1
13C6 PFDA	87		50 - 200	06/20/23 07:25	06/22/23 00:13	1
13C7 PFUnA	84		50 - 200	06/20/23 07:25	06/22/23 00:13	1
13C2 PFDoA	81		50 - 200	06/20/23 07:25	06/22/23 00:13	1
13C3 HFPO-DA	80		50 - 200	06/20/23 07:25	06/22/23 00:13	1
13C3 PFBS	82		50 - 200	06/20/23 07:25	06/22/23 00:13	1
13C8 PFOS	86		50 - 200	06/20/23 07:25	06/22/23 00:13	1
13C2-4:2-FTS	75		50 - 200	06/20/23 07:25	06/22/23 00:13	1
13C2-6:2-FTS	73		50 - 200	06/20/23 07:25	06/22/23 00:13	1
13C2-8:2-FTS	95		50 - 200	06/20/23 07:25	06/22/23 00:13	1
13C3 PFHxS	85		50 - 200	06/20/23 07:25	06/22/23 00:13	1

Client Sample ID: J18-Rehobeth ARV

Lab Sample ID: 810-65927-3

Date Collected: 06/09/23 09:30

Matrix: Drinking Water

Date Received: 06/12/23 08:45

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorobutanoic acid (PFBA)	3.6		1.9		ng/L		06/20/23 07:25	06/22/23 00:26	1
Perfluoropentanoic acid (PFPeA)	7.5		1.9		ng/L		06/20/23 07:25	06/22/23 00:26	1
Perfluorohexanoic acid (PFHxA)	7.4		1.9		ng/L		06/20/23 07:25	06/22/23 00:26	1
Perfluoroheptanoic acid (PFHpA)	2.6		1.9		ng/L		06/20/23 07:25	06/22/23 00:26	1
Perfluorooctanoic acid (PFOA)	4.2		1.9		ng/L		06/20/23 07:25	06/22/23 00:26	1
Perfluorononanoic acid (PFNA)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:26	1
Perfluorodecanoic acid (PFDA)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:26	1
Perfluoroundecanoic acid (PFUnA)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:26	1
Perfluorododecanoic acid (PFDoA)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:26	1
Perfluorobutanesulfonic acid (PFBS)	2.3		1.9		ng/L		06/20/23 07:25	06/22/23 00:26	1
Perfluoropentanesulfonic acid (PFPeS)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:26	1
Perfluorohexanesulfonic acid (PFHxS)	2.0		1.9		ng/L		06/20/23 07:25	06/22/23 00:26	1
Perfluoroheptanesulfonic acid (PFHpS)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:26	1
Perfluorooctanesulfonic acid (PFOS)	3.0		1.9		ng/L		06/20/23 07:25	06/22/23 00:26	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:26	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:26	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:26	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:26	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:26	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:26	1
9-Chlorohexadecafluoro-3-oxanonan e-1-sulfonic acid	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:26	1

Eurofins Eaton Analytical South Bend

Client Sample Results

Client: Union County Water
 Project/Site: PFAS - 533

Job ID: 810-65927-1

Client Sample ID: J18-Rehobeth ARV

Lab Sample ID: 810-65927-3

Date Collected: 06/09/23 09:30

Matrix: Drinking Water

Date Received: 06/12/23 08:45

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecan e-1-sulfonic acid	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:26	1
Perfluoro(4-methoxybutanoic acid)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:26	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:26	1
Perfluoro-3,6-dioxahheptanoic acid	<1.9		1.9		ng/L		06/20/23 07:25	06/22/23 00:26	1
Isotope Dilution	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
13C4 PFBA	89		50 - 200				06/20/23 07:25	06/22/23 00:26	1
13C5 PFPeA	142		50 - 200				06/20/23 07:25	06/22/23 00:26	1
13C5 PFHxA	83		50 - 200				06/20/23 07:25	06/22/23 00:26	1
13C4 PFHpA	86		50 - 200				06/20/23 07:25	06/22/23 00:26	1
13C8 PFOA	80		50 - 200				06/20/23 07:25	06/22/23 00:26	1
13C9 PFNA	92		50 - 200				06/20/23 07:25	06/22/23 00:26	1
13C6 PFDA	86		50 - 200				06/20/23 07:25	06/22/23 00:26	1
13C7 PFUnA	84		50 - 200				06/20/23 07:25	06/22/23 00:26	1
13C2 PFDoA	81		50 - 200				06/20/23 07:25	06/22/23 00:26	1
13C3 HFPO-DA	84		50 - 200				06/20/23 07:25	06/22/23 00:26	1
13C3 PFBS	87		50 - 200				06/20/23 07:25	06/22/23 00:26	1
13C8 PFOS	90		50 - 200				06/20/23 07:25	06/22/23 00:26	1
13C2-4:2-FTS	91		50 - 200				06/20/23 07:25	06/22/23 00:26	1
13C2-6:2-FTS	82		50 - 200				06/20/23 07:25	06/22/23 00:26	1
13C2-8:2-FTS	101		50 - 200				06/20/23 07:25	06/22/23 00:26	1
13C3 PFHxS	88		50 - 200				06/20/23 07:25	06/22/23 00:26	1

Isotope Dilution Summary

Client: Union County Water
Project/Site: PFAS - 533

Job ID: 810-65927-1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Matrix: Drinking Water

Prep Type: Total/NA

		Percent Isotope Dilution Recovery (Acceptance Limits)							
Lab Sample ID	Client Sample ID	PFBA (50-200)	PFPeA (50-200)	13C5PHA (50-200)	C4PFHA (50-200)	C8PFOA (50-200)	C9PFNA (50-200)	C6PFDA (50-200)	13C7PUA (50-200)
810-65927-1	T07-Hwy 74 E BPS	90	132	87	90	87	100	94	94
810-65927-2	NOR-Norwood WTP	84	121	79	82	80	92	87	84
810-65927-3	J18-Rehobeth ARV	89	142	83	86	80	92	86	84
LLCS 810-63060/2-A	Lab Control Sample	94	93	95	96	95	102	95	92
MBL 810-63060/1-A	Method Blank	96	94	95	95	95	101	92	88

		Percent Isotope Dilution Recovery (Acceptance Limits)							
Lab Sample ID	Client Sample ID	PFDoA (50-200)	HFPODA (50-200)	C3PFBS (50-200)	C8PFOS (50-200)	42FTS (50-200)	62FTS (50-200)	82FTS (50-200)	C3PFHS (50-200)
810-65927-1	T07-Hwy 74 E BPS	96	89	90	94	84	81	101	95
810-65927-2	NOR-Norwood WTP	81	80	82	86	75	73	95	85
810-65927-3	J18-Rehobeth ARV	81	84	87	90	91	82	101	88
LLCS 810-63060/2-A	Lab Control Sample	91	91	95	94	104	97	100	94
MBL 810-63060/1-A	Method Blank	85	91	94	93	103	95	96	92

Surrogate Legend

- PFBA = 13C4 PFBA
- PFPeA = 13C5 PFPeA
- 13C5PHA = 13C5 PFHxA
- C4PFHA = 13C4 PFHpA
- C8PFOA = 13C8 PFOA
- C9PFNA = 13C9 PFNA
- C6PFDA = 13C6 PFDA
- 13C7PUA = 13C7 PFUnA
- PFDoA = 13C2 PFDoA
- HFPODA = 13C3 HFPO-DA
- C3PFBS = 13C3 PFBS
- C8PFOS = 13C8 PFOS
- 42FTS = 13C2-4:2-FTS
- 62FTS = 13C2-6:2-FTS
- 82FTS = 13C2-8:2-FTS
- C3PFHS = 13C3 PFHxS

QC Sample Results

Client: Union County Water
Project/Site: PFAS - 533

Job ID: 810-65927-1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Lab Sample ID: MBL 810-63060/1-A
Matrix: Drinking Water
Analysis Batch: 63109

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 63060

Analyte	MBL Result	MBL Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorobutanoic acid (PFBA)	<0.52		2.0		ng/L		06/20/23 07:25	06/21/23 19:11	1
Perfluoropentanoic acid (PFPeA)	<0.38		2.0		ng/L		06/20/23 07:25	06/21/23 19:11	1
Perfluorohexanoic acid (PFHxA)	<0.42		2.0		ng/L		06/20/23 07:25	06/21/23 19:11	1
Perfluoroheptanoic acid (PFHpA)	<0.40		2.0		ng/L		06/20/23 07:25	06/21/23 19:11	1
Perfluorooctanoic acid (PFOA)	<0.38		2.0		ng/L		06/20/23 07:25	06/21/23 19:11	1
Perfluorononanoic acid (PFNA)	<0.38		2.0		ng/L		06/20/23 07:25	06/21/23 19:11	1
Perfluorodecanoic acid (PFDA)	<0.36		2.0		ng/L		06/20/23 07:25	06/21/23 19:11	1
Perfluoroundecanoic acid (PFUnA)	<0.38		2.0		ng/L		06/20/23 07:25	06/21/23 19:11	1
Perfluorododecanoic acid (PFDoA)	<0.35		2.0		ng/L		06/20/23 07:25	06/21/23 19:11	1
Perfluorobutanesulfonic acid (PFBS)	<0.42		2.0		ng/L		06/20/23 07:25	06/21/23 19:11	1
Perfluoropentanesulfonic acid (PFPeS)	<0.37		2.0		ng/L		06/20/23 07:25	06/21/23 19:11	1
Perfluorohexanesulfonic acid (PFHxS)	<0.39		2.0		ng/L		06/20/23 07:25	06/21/23 19:11	1
Perfluoroheptanesulfonic acid (PFHpS)	<0.44		2.0		ng/L		06/20/23 07:25	06/21/23 19:11	1
Perfluorooctanesulfonic acid (PFOS)	<0.39		2.0		ng/L		06/20/23 07:25	06/21/23 19:11	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<0.45		2.0		ng/L		06/20/23 07:25	06/21/23 19:11	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<0.56		2.0		ng/L		06/20/23 07:25	06/21/23 19:11	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<0.68		2.0		ng/L		06/20/23 07:25	06/21/23 19:11	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<0.57		2.0		ng/L		06/20/23 07:25	06/21/23 19:11	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	<0.53		2.0		ng/L		06/20/23 07:25	06/21/23 19:11	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.40		2.0		ng/L		06/20/23 07:25	06/21/23 19:11	1
9-Chlorohexadecafluoro-3-oxanonan e-1-sulfonic acid	<0.45		2.0		ng/L		06/20/23 07:25	06/21/23 19:11	1
11-Chloroeicosafluoro-3-oxaundecan e-1-sulfonic acid	<0.51		2.0		ng/L		06/20/23 07:25	06/21/23 19:11	1
Perfluoro(4-methoxybutanoic acid)	<0.35		2.0		ng/L		06/20/23 07:25	06/21/23 19:11	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<0.32		2.0		ng/L		06/20/23 07:25	06/21/23 19:11	1
Perfluoro-3,6-dioxaheptanoic acid	<0.93		2.0		ng/L		06/20/23 07:25	06/21/23 19:11	1

Isotope Dilution	MBL %Recovery	MBL Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C4 PFBA	96		50 - 200	06/20/23 07:25	06/21/23 19:11	1
13C5 PFPeA	94		50 - 200	06/20/23 07:25	06/21/23 19:11	1
13C5 PFHxA	95		50 - 200	06/20/23 07:25	06/21/23 19:11	1
13C4 PFHpA	95		50 - 200	06/20/23 07:25	06/21/23 19:11	1
13C8 PFOA	95		50 - 200	06/20/23 07:25	06/21/23 19:11	1
13C9 PFNA	101		50 - 200	06/20/23 07:25	06/21/23 19:11	1
13C6 PFDA	92		50 - 200	06/20/23 07:25	06/21/23 19:11	1
13C7 PFUnA	88		50 - 200	06/20/23 07:25	06/21/23 19:11	1
13C2 PFDoA	85		50 - 200	06/20/23 07:25	06/21/23 19:11	1
13C3 HFPO-DA	91		50 - 200	06/20/23 07:25	06/21/23 19:11	1
13C3 PFBS	94		50 - 200	06/20/23 07:25	06/21/23 19:11	1
13C8 PFOS	93		50 - 200	06/20/23 07:25	06/21/23 19:11	1
13C2-4:2-FTS	103		50 - 200	06/20/23 07:25	06/21/23 19:11	1

Eurofins Eaton Analytical South Bend

QC Sample Results

Client: Union County Water
Project/Site: PFAS - 533

Job ID: 810-65927-1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MBL 810-63060/1-A
Matrix: Drinking Water
Analysis Batch: 63109

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 63060

Isotope Dilution	MBL MBL		Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
13C2-6:2-FTS	95		50 - 200	06/20/23 07:25	06/21/23 19:11	1
13C2-8:2-FTS	96		50 - 200	06/20/23 07:25	06/21/23 19:11	1
13C3 PFHxS	92		50 - 200	06/20/23 07:25	06/21/23 19:11	1

Lab Sample ID: LLCS 810-63060/2-A
Matrix: Drinking Water
Analysis Batch: 63109

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 63060

Analyte	Spike Added	LLCS LLCS		Unit	D	%Rec	%Rec Limits
		Result	Qualifier				
Perfluorobutanoic acid (PFBA)	2.00	1.75	J	ng/L		88	50 - 150
Perfluoropentanoic acid (PFPeA)	2.00	1.76	J	ng/L		88	50 - 150
Perfluorohexanoic acid (PFHxA)	2.00	1.79	J	ng/L		89	50 - 150
Perfluoroheptanoic acid (PFHpA)	2.00	1.77	J	ng/L		88	50 - 150
Perfluorooctanoic acid (PFOA)	2.00	1.81	J	ng/L		90	50 - 150
Perfluorononanoic acid (PFNA)	2.00	1.82	J	ng/L		91	50 - 150
Perfluorodecanoic acid (PFDA)	2.00	1.84	J	ng/L		92	50 - 150
Perfluoroundecanoic acid (PFUnA)	2.00	1.76	J	ng/L		88	50 - 150
Perfluorododecanoic acid (PFDoA)	2.00	1.78	J	ng/L		89	50 - 150
Perfluorobutanesulfonic acid (PFBS)	1.78	1.51	J	ng/L		85	50 - 150
Perfluoropentanesulfonic acid (PFPeS)	1.88	1.56	J	ng/L		83	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	1.83	1.54	J	ng/L		84	50 - 150
Perfluoroheptanesulfonic acid (PFHpS)	1.91	1.55	J	ng/L		81	50 - 150
Perfluorooctanesulfonic acid (PFOS)	1.86	1.61	J	ng/L		87	50 - 150
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	1.78	1.53	J	ng/L		86	50 - 150
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	1.88	1.76	J	ng/L		94	50 - 150
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	1.90	1.87	J	ng/L		98	50 - 150
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	1.92	1.82	J	ng/L		95	50 - 150
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	2.00	1.70	J	ng/L		85	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	1.89	1.68	J	ng/L		89	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	1.87	1.47	J	ng/L		79	50 - 150
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	1.89	1.55	J	ng/L		82	50 - 150
Perfluoro(4-methoxybutanoic acid)	2.00	1.74	J	ng/L		87	50 - 150
Perfluoro-3-methoxypropanoic acid (PFMPA)	2.00	1.70	J	ng/L		85	50 - 150
Perfluoro-3,6-dioxaheptanoic acid	2.00	1.99	J	ng/L		100	50 - 150

QC Sample Results

Client: Union County Water
 Project/Site: PFAS - 533

Job ID: 810-65927-1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

<i>Isotope Dilution</i>	<i>LLCS LLCS</i>		<i>Limits</i>
	<i>%Recovery</i>	<i>Qualifier</i>	
13C4 PFBA	94		50 - 200
13C5 PFPeA	93		50 - 200
13C5 PFHxA	95		50 - 200
13C4 PFHpA	96		50 - 200
13C8 PFOA	95		50 - 200
13C9 PFNA	102		50 - 200
13C6 PFDA	95		50 - 200
13C7 PFUnA	92		50 - 200
13C2 PFDoA	91		50 - 200
13C3 HFPO-DA	91		50 - 200
13C3 PFBS	95		50 - 200
13C8 PFOS	94		50 - 200
13C2-4:2-FTS	104		50 - 200
13C2-6:2-FTS	97		50 - 200
13C2-8:2-FTS	100		50 - 200
13C3 PFHxS	94		50 - 200

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15

QC Association Summary

Client: Union County Water
Project/Site: PFAS - 533

Job ID: 810-65927-1

LCMS

Prep Batch: 63060

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-65927-1	T07-Hwy 74 E BPS	Total/NA	Drinking Water	533	
810-65927-2	NOR-Norwood WTP	Total/NA	Drinking Water	533	
810-65927-3	J18-Rehobeth ARV	Total/NA	Drinking Water	533	
MBL 810-63060/1-A	Method Blank	Total/NA	Drinking Water	533	
LLCS 810-63060/2-A	Lab Control Sample	Total/NA	Drinking Water	533	

Analysis Batch: 63109

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-65927-1	T07-Hwy 74 E BPS	Total/NA	Drinking Water	533	63060
810-65927-2	NOR-Norwood WTP	Total/NA	Drinking Water	533	63060
810-65927-3	J18-Rehobeth ARV	Total/NA	Drinking Water	533	63060
MBL 810-63060/1-A	Method Blank	Total/NA	Drinking Water	533	63060
LLCS 810-63060/2-A	Lab Control Sample	Total/NA	Drinking Water	533	63060

Lab Chronicle

Client: Union County Water
Project/Site: PFAS - 533

Job ID: 810-65927-1

Client Sample ID: T07-Hwy 74 E BPS

Lab Sample ID: 810-65927-1

Date Collected: 06/09/23 08:25

Matrix: Drinking Water

Date Received: 06/12/23 08:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			63060	MP	EA SB	06/20/23 07:25
Total/NA	Analysis	533		1	63109	CM	EA SB	06/22/23 00:01

Client Sample ID: NOR-Norwood WTP

Lab Sample ID: 810-65927-2

Date Collected: 06/09/23 09:21

Matrix: Drinking Water

Date Received: 06/12/23 08:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			63060	MP	EA SB	06/20/23 07:25
Total/NA	Analysis	533		1	63109	CM	EA SB	06/22/23 00:13

Client Sample ID: J18-Rehobeth ARV

Lab Sample ID: 810-65927-3

Date Collected: 06/09/23 09:30

Matrix: Drinking Water

Date Received: 06/12/23 08:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			63060	MP	EA SB	06/20/23 07:25
Total/NA	Analysis	533		1	63109	CM	EA SB	06/22/23 00:26

Laboratory References:

EA SB = Eurofins Eaton Analytical South Bend, 110 S Hill Street, South Bend, IN 46617, TEL (574)233-4777



Accreditation/Certification Summary

Client: Union County Water
 Project/Site: PFAS - 533

Job ID: 810-65927-1

Laboratory: Eurofins Eaton Analytical South Bend

Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Program	Identification Number	Expiration Date
North Carolina (DW)	State	18700	07-31-23

The following analytes are included in this report, but the laboratory is not certified by the governing authority. This list may include analytes for which the agency does not offer certification.

Analysis Method	Prep Method	Matrix	Analyte
533	533	Drinking Water	11-Chloroeicosafuoro-3-oxaundecane-1-sulfonic acid
533	533	Drinking Water	1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)
533	533	Drinking Water	1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)
533	533	Drinking Water	1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)
533	533	Drinking Water	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)
533	533	Drinking Water	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid
533	533	Drinking Water	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)
533	533	Drinking Water	Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)
533	533	Drinking Water	Perfluoro(4-methoxybutanoic acid)
533	533	Drinking Water	Perfluoro-3,6-dioxaheptanoic acid
533	533	Drinking Water	Perfluoro-3-methoxypropanoic acid (PFMPA)
533	533	Drinking Water	Perfluorobutanesulfonic acid (PFBS)
533	533	Drinking Water	Perfluorobutanoic acid (PFBA)
533	533	Drinking Water	Perfluorodecanoic acid (PFDA)
533	533	Drinking Water	Perfluorododecanoic acid (PFDoA)
533	533	Drinking Water	Perfluoroheptanesulfonic acid (PFHpS)
533	533	Drinking Water	Perfluoroheptanoic acid (PFHpA)
533	533	Drinking Water	Perfluorohexanesulfonic acid (PFHxS)
533	533	Drinking Water	Perfluorohexanoic acid (PFHxA)
533	533	Drinking Water	Perfluorononanoic acid (PFNA)
533	533	Drinking Water	Perfluorooctanesulfonic acid (PFOS)
533	533	Drinking Water	Perfluorooctanoic acid (PFOA)
533	533	Drinking Water	Perfluoropentanesulfonic acid (PFPeS)
533	533	Drinking Water	Perfluoropentanoic acid (PFPeA)
533	533	Drinking Water	Perfluoroundecanoic acid (PFUnA)

Method Summary

Client: Union County Water
Project/Site: PFAS - 533

Job ID: 810-65927-1

Method	Method Description	Protocol	Laboratory
533	Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water	EPA	EA SB
533	Extraction of Perfluorinated and Polyfluorinated Alkyl Acids	EPA	EA SB

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

EA SB = Eurofins Eaton Analytical South Bend, 110 S Hill Street, South Bend, IN 46617, TEL (574)233-4777



Sample Summary

Client: Union County Water
Project/Site: PFAS - 533

Job ID: 810-65927-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
810-65927-1	T07-Hwy 74 E BPS	Drinking Water	06/09/23 08:25	06/12/23 08:45
810-65927-2	NOR-Norwood WTP	Drinking Water	06/09/23 09:21	06/12/23 08:45
810-65927-3	J18-Rehobeth ARV	Drinking Water	06/09/23 09:30	06/12/23 08:45

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

Chain of Custody Record



110 S Hill Street
South Bend, IN 46617
Phone: 574-233-4777 Fax: 574-233-8207

Client Information

Client Contact: Justin Huntley
Company: Union County Water
Address: 500 N Main St.
City: NC, 28112

Sampler: Jordan Helms/Chris Tye
Phone: 980-269-7128

Lab P/N: Mathheis, Joe
E-Mail: Joe.Mathheis@et.eurofins.com

Carrier Tracking No(s):

COC No: 810-22200-6174.1
Page: Page 1 of 1

Due Date Requested:

TAT Requested (days):

Compliance Project: Yes No

PO #:

Purchase Order not required

WO #:

Project #:

PFAS - 533

Site:

SSOW#:

Project Name: Justin Huntley@UnionCountyNC.gov

Sample Identification

Sample Date

Sample Time

Sample Type (C=Comp, G=grab)

Matrix (Water, Solid, Other)

Preservation Code:

Field Filtered Sample (Yes or No)

Perform MS/MSD (Yes or No)

533 - (MOD) Local Method

Analysis Requested

Barcode: 810-65927 Chain of Custody

Total Number of containers

Special Instructions/Note:

Preservation Codes:

A - HCl
B - NaOH
C - Nitric Acid
D - NaHSO4
E - MeOH
F - Ammonia
G - Ascorbic Acid
H - Ice
I - DI Water
J - EDTA
K - EDTA
L - EDTA
M - Hexane
N - None
O - AsNaO2
P - Na2SO3
Q - Na2S2O3
R - Na2S2O3
S - H2SO4
T - TSP Decahydrate
U - Acetone
V - MCAA
W - pH 4-5
X - Trizma
Y - Trizma
Z - other (specify)

Possible Hazard Identification
 Non-Hazard Flammable Skin Irritant Poison B Unknown Radiological

Deliverable Requested: I, II, III, IV, Other (specify)

Empty Kit Relinquished by: _____ Date: _____

Relinquished by: Jordan Helms Date/Time: 6/9/23 / 11:14 Company: UC

Relinquished by: Chris Tye Date/Time: 6/9/23 Company: _____

Custody Seals Intact: Yes No Custody Seal No: _____

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
 Return To Client Disposal By Lab Archive For _____ Months

Special Instructions/QC Requirements:

Received by: Chris Tye Date/Time: 6/9/23 / 11:14 Company: UC

Received by: _____ Date/Time: _____ Company: _____

Received by: _____ Date/Time: _____ Company: _____

Cooler Temperature(s) °C and Other Remarks: _____

Initial Temp: _____
Refriger Temp: _____
Freeze Temp: _____

Eurofins Eaton Analytical South Bend



Englewood, Colorado 80112

110 S Hill Street
 South Bend, IN 46617
 Phone: 574-233-4777 Fax: 574-233-8207

Client Information

Client Contact: Justin Huntley
 Company: Union County Water
 Address: 500 N Main St.
 State Zip: NC, 28112
 Phone: 704-289-3307 (Tel)
 Email: Justin.Huntley@UnionCountyNC.gov
 Project Name: PFAS - 533
 Site: SSO#

Sampler: Jordan Helms/Chris Tye
 Phone: 980-269-7128
 Lab PM: Matthew S. Joe
 E-Mail: Joe.Matthews@etl.eurofins.com
 Carrier Tracking No(s):
 State of Origin:
 COC No: 810-22200-6174.1
 Page: Page 1 of 1
 Job #:

Analysis Requested

Due Date Requested:
 TAT Requested (days):
 Compliance Project: Yes No
 Purchase Order not required
 Project #: 81004979
 WOI #:
 Field Filtered Sample (Yes or No):
 Perform MS/MSD (Yes or No): 533 - (MOD) Local Method
 Barcode: 810-65927 Chain of Custody

Preservation Codes:
 A - HCL
 B - NaOH
 C - Zn Acetate
 D - Nitric Acid
 E - Nitrogen
 F - MeOH
 G - Amchlor
 H - Ascorbic Acid
 I - Ice
 J - DI Water
 K - EDTA
 L - EDTA
 M - Hexane
 N - None
 O - AsNaO2
 P - Na2OAS
 Q - Na2SO3
 R - Na2S2O3
 S - H2SO4
 T - TSP Dodecahydrate
 U - Acetone
 V - MCAA
 W - pH 4.5
 Y - Trizma
 Z - other (Specify)
 Other:

Sample Identification	Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (Sensit., Standard, Operational, BI=Inhouse Analy)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Special Instructions/Note:
TOT - HWY 74 E BPS	6/9/23	8:25A	G	Drinking Water			
NOR - Norwood WTP	6/9/23	9:21A	G	Drinking Water			
JIR - Rehebeth ARV	6/9/23	9:30A	G	Drinking Water			DK to proceed per 6/23

Possible Hazard Identification

Non-Hazard Flammable Skin Irritant Poison B Unknown Radiological

Deliverable Requested: I, II, III, IV, Other (specify)

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)

Return To Client Disposal By Lab Archive For _____ Months

Empty Kit Relinquished by: _____ Date: _____

Relinquished by: *Jordan Helms* Date/Time: 6/9/23 / 11:14 Company: UIC

Relinquished by: *Chris Tye* Date/Time: 6/9/23 Company: _____

Relinquished by: _____ Date/Time: _____ Company: _____

Custody Seals Intact: Yes No Custody Seal No: _____

Special Instructions/OC Requirements:

Received by: *Chris Tye* Date/Time: 6/9/23 / 11:14 Company: UIC

Received by: *KOR* Date/Time: 6-12-23 ORES Company: _____

Cooler Temperature(s) °C and Other Remarks: *was modeled*

Login Sample Receipt Checklist

Client: Union County Water

Job Number: 810-65927-1

Login Number: 65927

List Source: Eurofins Eaton Analytical South Bend

List Number: 1

Creator: DePriest, Kellie

Question	Answer	Comment
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
Samples were received on ice.	True	Water present in cooler; indicates evidence of melted ice.
Cooler Temperature is acceptable.	False	Cooler temperature outside required temperature criteria.
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	

