



Invitation for Bid No. 2024-049

**762 Pressure Zone Water Transmission Main
and Finished Water Pump Station**

.....

ADDENDUM No. 3

ISSUE DATE: January 26, 2024

Responding Offerors on this project are hereby notified that this Addendum shall be made a part of the above named IFB document.

The following items add to, modify, and/or clarify the IFB documents and shall have the full force and effect of the original Documents. This Addendum shall be acknowledged by the Offeror in the IFB document.

ADDENDUM NO. 3

TO PROSPECTIVE BIDDERS UNDER
762 Pressure Zone Water Transmission Main and Finished Water Pump Station
Invitation for Bid No. 2024-049
NCDEQ#: SRP-D-ARP-0161
Union County, NC

RECEIPT OF THIS ADDENDUM MUST BE ACKNOWLEDGED IN THE
SPACE PROVIDED IN THE BID FORM IN SECTION C-410

Addendum Item	Page or Drawing	Location and Description of Change
PART A - TECHNICAL SPECIFICATIONS		
1.	33 05 31	<p>Modify the following:</p> <p>Delete existing 2.07 (Joints) item B (Restrained Joints) paragraph 1. Add new paragraph, as follows:</p> <p><i>1. General: Restrained joints are required around pipe fittings at lengths as shown on the Restrained Joint Pipe Length Tables detail on sheet C-00-804. Unless otherwise specified, restrained joints shall be flanged or grooved end for exposed service and restrained push-on for buried service.</i></p>

This addendum shall be incorporated into and made a part of the Contract Documents

****END OF SECTION****