

 **ANALYTICAL REPORT****PREPARED FOR**

Attn: Justin Huntley  
Union County Water  
500 N Main St.  
Monroe, North Carolina 28112

Generated 12/6/2023 9:21:55 PM

**JOB DESCRIPTION**

PFAS - 533

**JOB NUMBER**

810-84317-1

# Eurofins Eaton Analytical South Bend

## Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and will meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Eaton Analytical, LLC Project Manager.

## Authorization



Generated  
12/6/2023 9:21:55 PM

Authorized for release by  
Joe Mattheis, Project Manager I  
[Joe.Mattheis@et.eurofinsus.com](mailto:Joe.Mattheis@et.eurofinsus.com)  
(574)233-4777



# Table of Contents

Cover Page . . . . .	1
Table of Contents . . . . .	3
Definitions/Glossary . . . . .	4
Case Narrative . . . . .	5
Detection Summary . . . . .	6
Client Sample Results . . . . .	7
Isotope Dilution Summary . . . . .	11
QC Sample Results . . . . .	12
QC Association Summary . . . . .	15
Lab Chronicle . . . . .	16
Certification Summary . . . . .	17
Method Summary . . . . .	18
Sample Summary . . . . .	19
Chain of Custody . . . . .	20
Receipt Checklists . . . . .	22

# Definitions/Glossary

Client: Union County Water  
Project/Site: PFAS - 533

Job ID: 810-84317-1

## Qualifiers

### LCMS

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

## Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
α	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

# Case Narrative

Client: Union County Water  
Project/Site: PFAS - 533

Job ID: 810-84317-1

---

**Job ID: 810-84317-1**

---

**Laboratory: Eurofins Eaton Analytical South Bend**

**Narrative**

---

**Job Narrative  
810-84317-1**

Analytical test results meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page unless otherwise noted under the individual analysis. Data qualifiers are applied to indicate exceptions. Noncompliant quality control (QC) is further explained in narrative comments.

Matrix QC may not be reported if insufficient sample or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD may be performed, unless otherwise specified in the method. Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

**Receipt**

The samples were received on 11/8/2023 9:00 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 0.2°C

**PFAS**

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.



# Detection Summary

Client: Union County Water  
Project/Site: PFAS - 533

Job ID: 810-84317-1

## Client Sample ID: J18 - Rehobeth ARV

Lab Sample ID: 810-84317-1

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Perfluorobutanoic acid (PFBA)	3.7		1.9		ng/L	1		533	Total/NA
Perfluoropentanoic acid (PFPeA)	9.9		1.9		ng/L	1		533	Total/NA
Perfluorohexanoic acid (PFHxA)	7.4		1.9		ng/L	1		533	Total/NA
Perfluoroheptanoic acid (PFHpA)	2.2		1.9		ng/L	1		533	Total/NA
Perfluorooctanoic acid (PFOA)	3.2		1.9		ng/L	1		533	Total/NA
Perfluorobutanesulfonic acid (PFBS)	1.9		1.9		ng/L	1		533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	2.1		1.9		ng/L	1		533	Total/NA

## Client Sample ID: T07 - Hwy 74 E BPS

Lab Sample ID: 810-84317-2

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Perfluorobutanoic acid (PFBA)	2.7		2.0		ng/L	1		533	Total/NA
Perfluoropentanoic acid (PFPeA)	4.2		2.0		ng/L	1		533	Total/NA
Perfluorohexanoic acid (PFHxA)	3.3		2.0		ng/L	1		533	Total/NA
Perfluorooctanoic acid (PFOA)	2.9		2.0		ng/L	1		533	Total/NA
Perfluorobutanesulfonic acid (PFBS)	2.0		2.0		ng/L	1		533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	4.0		2.0		ng/L	1		533	Total/NA

## Client Sample ID: N0R - Norwood WTP

Lab Sample ID: 810-84317-3

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Perfluorobutanoic acid (PFBA)	2.5		2.0		ng/L	1		533	Total/NA
Perfluoropentanoic acid (PFPeA)	3.2		2.0		ng/L	1		533	Total/NA
Perfluorohexanoic acid (PFHxA)	2.8		2.0		ng/L	1		533	Total/NA
Perfluorooctanoic acid (PFOA)	2.5		2.0		ng/L	1		533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	4.2		2.0		ng/L	1		533	Total/NA

This Detection Summary does not include radiochemical test results.

Eurofins Eaton Analytical South Bend

# Client Sample Results

Client: Union County Water  
Project/Site: PFAS - 533

Job ID: 810-84317-1

**Client Sample ID: J18 - Rehobeth ARV**

**Lab Sample ID: 810-84317-1**

Date Collected: 11/07/23 09:14

Matrix: Drinking Water

Date Received: 11/08/23 09:00

**Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorobutanoic acid (PFBA)	3.7		1.9		ng/L		11/21/23 15:08	11/23/23 00:39	1
Perfluoropentanoic acid (PFPeA)	9.9		1.9		ng/L		11/21/23 15:08	11/23/23 00:39	1
Perfluorohexanoic acid (PFHxA)	7.4		1.9		ng/L		11/21/23 15:08	11/23/23 00:39	1
Perfluoroheptanoic acid (PFHpA)	2.2		1.9		ng/L		11/21/23 15:08	11/23/23 00:39	1
Perfluorooctanoic acid (PFOA)	3.2		1.9		ng/L		11/21/23 15:08	11/23/23 00:39	1
Perfluorononanoic acid (PFNA)	<1.9		1.9		ng/L		11/21/23 15:08	11/23/23 00:39	1
Perfluorodecanoic acid (PFDA)	<1.9		1.9		ng/L		11/21/23 15:08	11/23/23 00:39	1
Perfluoroundecanoic acid (PFUnA)	<1.9		1.9		ng/L		11/21/23 15:08	11/23/23 00:39	1
Perfluorododecanoic acid (PFDoA)	<1.9		1.9		ng/L		11/21/23 15:08	11/23/23 00:39	1
Perfluorobutanesulfonic acid (PFBS)	1.9		1.9		ng/L		11/21/23 15:08	11/23/23 00:39	1
Perfluoropentanesulfonic acid (PFPeS)	<1.9		1.9		ng/L		11/21/23 15:08	11/23/23 00:39	1
Perfluorohexanesulfonic acid (PFHxS)	<1.9		1.9		ng/L		11/21/23 15:08	11/23/23 00:39	1
Perfluoroheptanesulfonic acid (PFHpS)	<1.9		1.9		ng/L		11/21/23 15:08	11/23/23 00:39	1
Perfluorooctanesulfonic acid (PFOS)	2.1		1.9		ng/L		11/21/23 15:08	11/23/23 00:39	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<1.9		1.9		ng/L		11/21/23 15:08	11/23/23 00:39	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<1.9		1.9		ng/L		11/21/23 15:08	11/23/23 00:39	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<1.9		1.9		ng/L		11/21/23 15:08	11/23/23 00:39	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<1.9		1.9		ng/L		11/21/23 15:08	11/23/23 00:39	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	<1.9		1.9		ng/L		11/21/23 15:08	11/23/23 00:39	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<1.9		1.9		ng/L		11/21/23 15:08	11/23/23 00:39	1
9-Chlorohexadecafluoro-3-oxanonan e-1-sulfonic acid	<1.9		1.9		ng/L		11/21/23 15:08	11/23/23 00:39	1
11-Chloroeicosafluoro-3-oxaundecan e-1-sulfonic acid	<1.9		1.9		ng/L		11/21/23 15:08	11/23/23 00:39	1
Perfluoro(4-methoxybutanoic acid)	<1.9		1.9		ng/L		11/21/23 15:08	11/23/23 00:39	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<1.9		1.9		ng/L		11/21/23 15:08	11/23/23 00:39	1
Perfluoro-3,6-dioxaheptanoic acid	<1.9		1.9		ng/L		11/21/23 15:08	11/23/23 00:39	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C4 PFBA	92		50 - 200	11/21/23 15:08	11/23/23 00:39	1
13C5 PFPeA	92		50 - 200	11/21/23 15:08	11/23/23 00:39	1
13C5 PFHxA	91		50 - 200	11/21/23 15:08	11/23/23 00:39	1
13C4 PFHpA	87		50 - 200	11/21/23 15:08	11/23/23 00:39	1
13C8 PFOA	86		50 - 200	11/21/23 15:08	11/23/23 00:39	1
13C9 PFNA	86		50 - 200	11/21/23 15:08	11/23/23 00:39	1
13C6 PFDA	83		50 - 200	11/21/23 15:08	11/23/23 00:39	1
13C7 PFUnA	84		50 - 200	11/21/23 15:08	11/23/23 00:39	1
13C2 PFDoA	82		50 - 200	11/21/23 15:08	11/23/23 00:39	1
13C3 HFPO-DA	83		50 - 200	11/21/23 15:08	11/23/23 00:39	1
13C3 PFBS	95		50 - 200	11/21/23 15:08	11/23/23 00:39	1
13C8 PFOS	96		50 - 200	11/21/23 15:08	11/23/23 00:39	1
13C2-4:2-FTS	108		50 - 200	11/21/23 15:08	11/23/23 00:39	1

Eurofins Eaton Analytical South Bend

# Client Sample Results

Client: Union County Water  
Project/Site: PFAS - 533

Job ID: 810-84317-1

**Client Sample ID: J18 - Rehobeth ARV**

**Lab Sample ID: 810-84317-1**

Date Collected: 11/07/23 09:14

Matrix: Drinking Water

Date Received: 11/08/23 09:00

**Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)**

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2-6:2-FTS	97		50 - 200	11/21/23 15:08	11/23/23 00:39	1
13C2-8:2-FTS	103		50 - 200	11/21/23 15:08	11/23/23 00:39	1
13C3 PFHxS	96		50 - 200	11/21/23 15:08	11/23/23 00:39	1

**Client Sample ID: T07 - Hwy 74 E BPS**

**Lab Sample ID: 810-84317-2**

Date Collected: 11/07/23 10:12

Matrix: Drinking Water

Date Received: 11/08/23 09:00

**Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorobutanoic acid (PFBA)	2.7		2.0		ng/L		11/21/23 15:08	11/23/23 00:53	1
Perfluoropentanoic acid (PFPeA)	4.2		2.0		ng/L		11/21/23 15:08	11/23/23 00:53	1
Perfluorohexanoic acid (PFHxA)	3.3		2.0		ng/L		11/21/23 15:08	11/23/23 00:53	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 00:53	1
Perfluorooctanoic acid (PFOA)	2.9		2.0		ng/L		11/21/23 15:08	11/23/23 00:53	1
Perfluorononanoic acid (PFNA)	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 00:53	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 00:53	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 00:53	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 00:53	1
Perfluorobutanesulfonic acid (PFBS)	2.0		2.0		ng/L		11/21/23 15:08	11/23/23 00:53	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 00:53	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 00:53	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 00:53	1
Perfluorooctanesulfonic acid (PFOS)	4.0		2.0		ng/L		11/21/23 15:08	11/23/23 00:53	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 00:53	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 00:53	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 00:53	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 00:53	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 00:53	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 00:53	1
9-Chlorohexadecafluoro-3-oxanonan e-1-sulfonic acid	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 00:53	1
11-Chloroeicosafluoro-3-oxaundecan e-1-sulfonic acid	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 00:53	1
Perfluoro(4-methoxybutanoic acid)	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 00:53	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 00:53	1
Perfluoro-3,6-dioxaheptanoic acid	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 00:53	1
<b>Isotope Dilution</b>	<b>%Recovery</b>	<b>Qualifier</b>	<b>Limits</b>				<b>Prepared</b>	<b>Analyzed</b>	<b>Dil Fac</b>
13C4 PFBA	94		50 - 200				11/21/23 15:08	11/23/23 00:53	1
13C5 PFPeA	92		50 - 200				11/21/23 15:08	11/23/23 00:53	1
13C5 PFHxA	94		50 - 200				11/21/23 15:08	11/23/23 00:53	1
13C4 PFHpA	89		50 - 200				11/21/23 15:08	11/23/23 00:53	1

Eurofins Eaton Analytical South Bend



# Client Sample Results

Client: Union County Water  
Project/Site: PFAS - 533

Job ID: 810-84317-1

**Client Sample ID: T07 - Hwy 74 E BPS**

**Lab Sample ID: 810-84317-2**

Date Collected: 11/07/23 10:12

Matrix: Drinking Water

Date Received: 11/08/23 09:00

**Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)**

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C8 PFOA	89		50 - 200	11/21/23 15:08	11/23/23 00:53	1
13C9 PFNA	88		50 - 200	11/21/23 15:08	11/23/23 00:53	1
13C6 PFDA	82		50 - 200	11/21/23 15:08	11/23/23 00:53	1
13C7 PFUnA	82		50 - 200	11/21/23 15:08	11/23/23 00:53	1
13C2 PFDoA	83		50 - 200	11/21/23 15:08	11/23/23 00:53	1
13C3 HFPO-DA	86		50 - 200	11/21/23 15:08	11/23/23 00:53	1
13C3 PFBS	94		50 - 200	11/21/23 15:08	11/23/23 00:53	1
13C8 PFOS	95		50 - 200	11/21/23 15:08	11/23/23 00:53	1
13C2-4:2-FTS	117		50 - 200	11/21/23 15:08	11/23/23 00:53	1
13C2-6:2-FTS	94		50 - 200	11/21/23 15:08	11/23/23 00:53	1
13C2-8:2-FTS	104		50 - 200	11/21/23 15:08	11/23/23 00:53	1
13C3 PFHxS	95		50 - 200	11/21/23 15:08	11/23/23 00:53	1

**Client Sample ID: N0R - Norwood WTP**

**Lab Sample ID: 810-84317-3**

Date Collected: 11/07/23 10:51

Matrix: Drinking Water

Date Received: 11/08/23 09:00

**Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorobutanoic acid (PFBA)	2.5		2.0		ng/L		11/21/23 15:08	11/23/23 01:06	1
Perfluoropentanoic acid (PFPeA)	3.2		2.0		ng/L		11/21/23 15:08	11/23/23 01:06	1
Perfluorohexanoic acid (PFHxA)	2.8		2.0		ng/L		11/21/23 15:08	11/23/23 01:06	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 01:06	1
Perfluorooctanoic acid (PFOA)	2.5		2.0		ng/L		11/21/23 15:08	11/23/23 01:06	1
Perfluorononanoic acid (PFNA)	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 01:06	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 01:06	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 01:06	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 01:06	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 01:06	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 01:06	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 01:06	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 01:06	1
Perfluorooctanesulfonic acid (PFOS)	4.2		2.0		ng/L		11/21/23 15:08	11/23/23 01:06	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 01:06	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 01:06	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 01:06	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 01:06	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 01:06	1
4,8-Dioxo-3H-perfluorononanoic acid (ADONA)	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 01:06	1
9-Chlorohexadecafluoro-3-oxanonan e-1-sulfonic acid	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 01:06	1
11-Chloroeicosafluoro-3-oxaundecan e-1-sulfonic acid	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 01:06	1
Perfluoro(4-methoxybutanoic acid)	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 01:06	1

Eurofins Eaton Analytical South Bend

# Client Sample Results

Client: Union County Water  
Project/Site: PFAS - 533

Job ID: 810-84317-1

**Client Sample ID: N0R - Norwood WTP**

**Lab Sample ID: 810-84317-3**

Date Collected: 11/07/23 10:51

Matrix: Drinking Water

Date Received: 11/08/23 09:00

**Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 01:06	1
Perfluoro-3,6-dioxaheptanoic acid	<2.0		2.0		ng/L		11/21/23 15:08	11/23/23 01:06	1
Isotope Dilution	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
13C4 PFBA	89		50 - 200				11/21/23 15:08	11/23/23 01:06	1
13C5 PFPeA	87		50 - 200				11/21/23 15:08	11/23/23 01:06	1
13C5 PFHxA	90		50 - 200				11/21/23 15:08	11/23/23 01:06	1
13C4 PFHpA	86		50 - 200				11/21/23 15:08	11/23/23 01:06	1
13C8 PFOA	84		50 - 200				11/21/23 15:08	11/23/23 01:06	1
13C9 PFNA	85		50 - 200				11/21/23 15:08	11/23/23 01:06	1
13C6 PFDA	77		50 - 200				11/21/23 15:08	11/23/23 01:06	1
13C7 PFUnA	73		50 - 200				11/21/23 15:08	11/23/23 01:06	1
13C2 PFDoA	75		50 - 200				11/21/23 15:08	11/23/23 01:06	1
13C3 HFPO-DA	83		50 - 200				11/21/23 15:08	11/23/23 01:06	1
13C3 PFBS	93		50 - 200				11/21/23 15:08	11/23/23 01:06	1
13C8 PFOS	91		50 - 200				11/21/23 15:08	11/23/23 01:06	1
13C2-4:2-FTS	108		50 - 200				11/21/23 15:08	11/23/23 01:06	1
13C2-6:2-FTS	93		50 - 200				11/21/23 15:08	11/23/23 01:06	1
13C2-8:2-FTS	96		50 - 200				11/21/23 15:08	11/23/23 01:06	1
13C3 PFHxS	93		50 - 200				11/21/23 15:08	11/23/23 01:06	1

# Isotope Dilution Summary

Client: Union County Water  
Project/Site: PFAS - 533

Job ID: 810-84317-1

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Matrix: Drinking Water

Prep Type: Total/NA

### Percent Isotope Dilution Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	PFBA (50-200)	PFPeA (50-200)	13C5PHA (50-200)	C4PFHA (50-200)	C8PFOA (50-200)	C9PFNA (50-200)	C6PFDA (50-200)	13C7PUA (50-200)
810-84317-1	J18 - Rehobeth ARV	92	92	91	87	86	86	83	84
810-84317-2	T07 - Hwy 74 E BPS	94	92	94	89	89	88	82	82
810-84317-3	N0R - Norwood WTP	89	87	90	86	84	85	77	73
LLCS 810-80741/2-A	Lab Control Sample	95	97	96	96	97	101	93	89
MBL 810-80741/1-A	Method Blank	95	96	96	96	98	101	99	96

### Percent Isotope Dilution Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	PFDoA (50-200)	HFPODA (50-200)	C3PFBS (50-200)	C8PFOS (50-200)	42FTS (50-200)	62FTS (50-200)	82FTS (50-200)	C3PFHS (50-200)
810-84317-1	J18 - Rehobeth ARV	82	83	95	96	108	97	103	96
810-84317-2	T07 - Hwy 74 E BPS	83	86	94	95	117	94	104	95
810-84317-3	N0R - Norwood WTP	75	83	93	91	108	93	96	93
LLCS 810-80741/2-A	Lab Control Sample	86	78	94	93	89	99	96	93
MBL 810-80741/1-A	Method Blank	94	78	97	96	92	108	104	97

#### Surrogate Legend

- PFBA = 13C4 PFBA
- PFPeA = 13C5 PFPeA
- 13C5PHA = 13C5 PFHxA
- C4PFHA = 13C4 PFHpA
- C8PFOA = 13C8 PFOA
- C9PFNA = 13C9 PFNA
- C6PFDA = 13C6 PFDA
- 13C7PUA = 13C7 PFUnA
- PFDoA = 13C2 PFDoA
- HFPODA = 13C3 HFPO-DA
- C3PFBS = 13C3 PFBS
- C8PFOS = 13C8 PFOS
- 42FTS = 13C2-4:2-FTS
- 62FTS = 13C2-6:2-FTS
- 82FTS = 13C2-8:2-FTS
- C3PFHS = 13C3 PFHxS

# QC Sample Results

Client: Union County Water  
Project/Site: PFAS - 533

Job ID: 810-84317-1

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

**Lab Sample ID: MBL 810-80741/1-A**  
**Matrix: Drinking Water**  
**Analysis Batch: 80890**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 80741**

Analyte	MBL Result	MBL Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorobutanoic acid (PFBA)	<0.52		2.0		ng/L		11/21/23 15:08	11/22/23 22:37	1
Perfluoropentanoic acid (PFPeA)	<0.38		2.0		ng/L		11/21/23 15:08	11/22/23 22:37	1
Perfluorohexanoic acid (PFHxA)	<0.42		2.0		ng/L		11/21/23 15:08	11/22/23 22:37	1
Perfluoroheptanoic acid (PFHpA)	<0.40		2.0		ng/L		11/21/23 15:08	11/22/23 22:37	1
Perfluorooctanoic acid (PFOA)	<0.38		2.0		ng/L		11/21/23 15:08	11/22/23 22:37	1
Perfluorononanoic acid (PFNA)	<0.38		2.0		ng/L		11/21/23 15:08	11/22/23 22:37	1
Perfluorodecanoic acid (PFDA)	<0.36		2.0		ng/L		11/21/23 15:08	11/22/23 22:37	1
Perfluoroundecanoic acid (PFUnA)	<0.38		2.0		ng/L		11/21/23 15:08	11/22/23 22:37	1
Perfluorododecanoic acid (PFDoA)	<0.35		2.0		ng/L		11/21/23 15:08	11/22/23 22:37	1
Perfluorobutanesulfonic acid (PFBS)	<0.42		2.0		ng/L		11/21/23 15:08	11/22/23 22:37	1
Perfluoropentanesulfonic acid (PFPeS)	<0.37		2.0		ng/L		11/21/23 15:08	11/22/23 22:37	1
Perfluorohexanesulfonic acid (PFHxS)	<0.39		2.0		ng/L		11/21/23 15:08	11/22/23 22:37	1
Perfluoroheptanesulfonic acid (PFHpS)	<0.44		2.0		ng/L		11/21/23 15:08	11/22/23 22:37	1
Perfluorooctanesulfonic acid (PFOS)	<0.39		2.0		ng/L		11/21/23 15:08	11/22/23 22:37	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<0.45		2.0		ng/L		11/21/23 15:08	11/22/23 22:37	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<0.56		2.0		ng/L		11/21/23 15:08	11/22/23 22:37	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<0.68		2.0		ng/L		11/21/23 15:08	11/22/23 22:37	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<0.57		2.0		ng/L		11/21/23 15:08	11/22/23 22:37	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	<0.53		2.0		ng/L		11/21/23 15:08	11/22/23 22:37	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.40		2.0		ng/L		11/21/23 15:08	11/22/23 22:37	1
9-Chlorohexadecafluoro-3-oxanonan e-1-sulfonic acid	<0.45		2.0		ng/L		11/21/23 15:08	11/22/23 22:37	1
11-Chloroeicosafluoro-3-oxaundecan e-1-sulfonic acid	<0.51		2.0		ng/L		11/21/23 15:08	11/22/23 22:37	1
Perfluoro(4-methoxybutanoic acid)	<0.35		2.0		ng/L		11/21/23 15:08	11/22/23 22:37	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<0.32		2.0		ng/L		11/21/23 15:08	11/22/23 22:37	1
Perfluoro-3,6-dioxaheptanoic acid	<0.93		2.0		ng/L		11/21/23 15:08	11/22/23 22:37	1

Isotope Dilution	MBL %Recovery	MBL Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C4 PFBA	95		50 - 200	11/21/23 15:08	11/22/23 22:37	1
13C5 PFPeA	96		50 - 200	11/21/23 15:08	11/22/23 22:37	1
13C5 PFHxA	96		50 - 200	11/21/23 15:08	11/22/23 22:37	1
13C4 PFHpA	96		50 - 200	11/21/23 15:08	11/22/23 22:37	1
13C8 PFOA	98		50 - 200	11/21/23 15:08	11/22/23 22:37	1
13C9 PFNA	101		50 - 200	11/21/23 15:08	11/22/23 22:37	1
13C6 PFDA	99		50 - 200	11/21/23 15:08	11/22/23 22:37	1
13C7 PFUnA	96		50 - 200	11/21/23 15:08	11/22/23 22:37	1
13C2 PFDoA	94		50 - 200	11/21/23 15:08	11/22/23 22:37	1
13C3 HFPO-DA	78		50 - 200	11/21/23 15:08	11/22/23 22:37	1
13C3 PFBS	97		50 - 200	11/21/23 15:08	11/22/23 22:37	1
13C8 PFOS	96		50 - 200	11/21/23 15:08	11/22/23 22:37	1
13C2-4:2-FTS	92		50 - 200	11/21/23 15:08	11/22/23 22:37	1

Eurofins Eaton Analytical South Bend

# QC Sample Results

Client: Union County Water  
Project/Site: PFAS - 533

Job ID: 810-84317-1

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

**Lab Sample ID: MBL 810-80741/1-A**  
**Matrix: Drinking Water**  
**Analysis Batch: 80890**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 80741**

Isotope Dilution	MBL MBL		Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
13C2-6:2-FTS	108		50 - 200	11/21/23 15:08	11/22/23 22:37	1
13C2-8:2-FTS	104		50 - 200	11/21/23 15:08	11/22/23 22:37	1
13C3 PFHxS	97		50 - 200	11/21/23 15:08	11/22/23 22:37	1

**Lab Sample ID: LLCS 810-80741/2-A**  
**Matrix: Drinking Water**  
**Analysis Batch: 80890**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 80741**

Analyte	Spike Added	LLCS LLCS		Unit	D	%Rec	%Rec Limits
		Result	Qualifier				
Perfluorobutanoic acid (PFBA)	2.00	1.90	J	ng/L		95	50 - 150
Perfluoropentanoic acid (PFPeA)	2.00	1.95	J	ng/L		98	50 - 150
Perfluorohexanoic acid (PFHxA)	2.00	1.98	J	ng/L		99	50 - 150
Perfluoroheptanoic acid (PFHpA)	2.00	1.92	J	ng/L		96	50 - 150
Perfluorooctanoic acid (PFOA)	2.00	1.94	J	ng/L		97	50 - 150
Perfluorononanoic acid (PFNA)	2.00	2.06		ng/L		103	50 - 150
Perfluorodecanoic acid (PFDA)	2.00	2.04		ng/L		102	50 - 150
Perfluoroundecanoic acid (PFUnA)	2.00	1.93	J	ng/L		97	50 - 150
Perfluorododecanoic acid (PFDoA)	2.00	1.97	J	ng/L		98	50 - 150
Perfluorobutanesulfonic acid (PFBS)	1.78	1.67	J	ng/L		94	50 - 150
Perfluoropentanesulfonic acid (PFPeS)	1.88	1.81	J	ng/L		96	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	1.83	1.73	J	ng/L		95	50 - 150
Perfluoroheptanesulfonic acid (PFHpS)	1.91	1.78	J	ng/L		93	50 - 150
Perfluorooctanesulfonic acid (PFOS)	1.86	1.88	J	ng/L		101	50 - 150
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	1.78	2.16		ng/L		121	50 - 150
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	1.88	1.94	J	ng/L		103	50 - 150
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	1.90	2.10		ng/L		111	50 - 150
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	1.92	1.97	J	ng/L		103	50 - 150
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	2.00	1.87	J	ng/L		94	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	1.89	1.92	J	ng/L		101	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	1.87	1.55	J	ng/L		83	50 - 150
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	1.89	1.65	J	ng/L		87	50 - 150
Perfluoro(4-methoxybutanoic acid)	2.00	1.88	J	ng/L		94	50 - 150
Perfluoro-3-methoxypropanoic acid (PFMPA)	2.00	1.98	J	ng/L		99	50 - 150
Perfluoro-3,6-dioxaheptanoic acid	2.00	1.90	J	ng/L		95	50 - 150

# QC Sample Results

Client: Union County Water  
 Project/Site: PFAS - 533

Job ID: 810-84317-1

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

<i>Isotope Dilution</i>	<i>LLCS LLCS</i>		<i>Limits</i>
	<i>%Recovery</i>	<i>Qualifier</i>	
13C4 PFBA	95		50 - 200
13C5 PFPeA	97		50 - 200
13C5 PFHxA	96		50 - 200
13C4 PFHpA	96		50 - 200
13C8 PFOA	97		50 - 200
13C9 PFNA	101		50 - 200
13C6 PFDA	93		50 - 200
13C7 PFUnA	89		50 - 200
13C2 PFDoA	86		50 - 200
13C3 HFPO-DA	78		50 - 200
13C3 PFBS	94		50 - 200
13C8 PFOS	93		50 - 200
13C2-4:2-FTS	89		50 - 200
13C2-6:2-FTS	99		50 - 200
13C2-8:2-FTS	96		50 - 200
13C3 PFHxS	93		50 - 200

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15

# QC Association Summary

Client: Union County Water  
 Project/Site: PFAS - 533

Job ID: 810-84317-1

## LCMS

### Prep Batch: 80741

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-84317-1	J18 - Rehobeth ARV	Total/NA	Drinking Water	533	
810-84317-2	T07 - Hwy 74 E BPS	Total/NA	Drinking Water	533	
810-84317-3	N0R - Norwood WTP	Total/NA	Drinking Water	533	
MBL 810-80741/1-A	Method Blank	Total/NA	Drinking Water	533	
LLCS 810-80741/2-A	Lab Control Sample	Total/NA	Drinking Water	533	

### Analysis Batch: 80890

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-84317-1	J18 - Rehobeth ARV	Total/NA	Drinking Water	533	80741
810-84317-2	T07 - Hwy 74 E BPS	Total/NA	Drinking Water	533	80741
810-84317-3	N0R - Norwood WTP	Total/NA	Drinking Water	533	80741
MBL 810-80741/1-A	Method Blank	Total/NA	Drinking Water	533	80741
LLCS 810-80741/2-A	Lab Control Sample	Total/NA	Drinking Water	533	80741



# Lab Chronicle

Client: Union County Water  
Project/Site: PFAS - 533

Job ID: 810-84317-1

**Client Sample ID: J18 - Rehobeth ARV**

**Lab Sample ID: 810-84317-1**

Date Collected: 11/07/23 09:14

Matrix: Drinking Water

Date Received: 11/08/23 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			80741	ER	EA SB	11/21/23 15:08
Total/NA	Analysis	533		1	80890	KB	EA SB	11/23/23 00:39

**Client Sample ID: T07 - Hwy 74 E BPS**

**Lab Sample ID: 810-84317-2**

Date Collected: 11/07/23 10:12

Matrix: Drinking Water

Date Received: 11/08/23 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			80741	ER	EA SB	11/21/23 15:08
Total/NA	Analysis	533		1	80890	KB	EA SB	11/23/23 00:53

**Client Sample ID: N0R - Norwood WTP**

**Lab Sample ID: 810-84317-3**

Date Collected: 11/07/23 10:51

Matrix: Drinking Water

Date Received: 11/08/23 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			80741	ER	EA SB	11/21/23 15:08
Total/NA	Analysis	533		1	80890	KB	EA SB	11/23/23 01:06

**Laboratory References:**

EA SB = Eurofins Eaton Analytical South Bend, 110 S Hill Street, South Bend, IN 46617, TEL (574)233-4777



# Accreditation/Certification Summary

Client: Union County Water  
 Project/Site: PFAS - 533

Job ID: 810-84317-1

## Laboratory: Eurofins Eaton Analytical South Bend

Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Program	Identification Number	Expiration Date
North Carolina (DW)	State	18700	07-31-24

The following analytes are included in this report, but the laboratory is not certified by the governing authority. This list may include analytes for which the agency does not offer certification.

Analysis Method	Prep Method	Matrix	Analyte
533	533	Drinking Water	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid
533	533	Drinking Water	1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)
533	533	Drinking Water	1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)
533	533	Drinking Water	1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)
533	533	Drinking Water	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)
533	533	Drinking Water	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid
533	533	Drinking Water	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)
533	533	Drinking Water	Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)
533	533	Drinking Water	Perfluoro(4-methoxybutanoic acid)
533	533	Drinking Water	Perfluoro-3,6-dioxaheptanoic acid
533	533	Drinking Water	Perfluoro-3-methoxypropanoic acid (PFMPA)
533	533	Drinking Water	Perfluorobutanesulfonic acid (PFBS)
533	533	Drinking Water	Perfluorobutanoic acid (PFBA)
533	533	Drinking Water	Perfluorodecanoic acid (PFDA)
533	533	Drinking Water	Perfluorododecanoic acid (PFDoA)
533	533	Drinking Water	Perfluoroheptanesulfonic acid (PFHpS)
533	533	Drinking Water	Perfluoroheptanoic acid (PFHpA)
533	533	Drinking Water	Perfluorohexanesulfonic acid (PFHxS)
533	533	Drinking Water	Perfluorohexanoic acid (PFHxA)
533	533	Drinking Water	Perfluorononanoic acid (PFNA)
533	533	Drinking Water	Perfluorooctanesulfonic acid (PFOS)
533	533	Drinking Water	Perfluorooctanoic acid (PFOA)
533	533	Drinking Water	Perfluoropentanesulfonic acid (PFPeS)
533	533	Drinking Water	Perfluoropentanoic acid (PFPeA)
533	533	Drinking Water	Perfluoroundecanoic acid (PFUnA)

# Method Summary

Client: Union County Water  
Project/Site: PFAS - 533

Job ID: 810-84317-1

Method	Method Description	Protocol	Laboratory
533	Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water	EPA	EA SB
533	Extraction of Perfluorinated and Polyfluorinated Alkyl Acids	EPA	EA SB

**Protocol References:**

EPA = US Environmental Protection Agency

**Laboratory References:**

EA SB = Eurofins Eaton Analytical South Bend, 110 S Hill Street, South Bend, IN 46617, TEL (574)233-4777



# Sample Summary

Client: Union County Water  
Project/Site: PFAS - 533

Job ID: 810-84317-1

---

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
810-84317-1	J18 - Rehobeth ARV	Drinking Water	11/07/23 09:14	11/08/23 09:00
810-84317-2	T07 - Hwy 74 E BPS	Drinking Water	11/07/23 10:12	11/08/23 09:00
810-84317-3	NOR - Norwood WTP	Drinking Water	11/07/23 10:51	11/08/23 09:00

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15



810-84317 Chain of Custody

### Chain of Custody Record



Sampler: **Chris Tye** Lab PM: **Matthews, Joe** Carner Tracking No(s): **810-22201-6174.1**  
 Phone: **950-417-0018** E-Mail: **Joe.Matthews@eurofins.com** State of Origin: **NC** Page: **1 of 1**  
 PWSID: **810-22201-6174.1** Job #: **810-22201-6174.1**

Company: **Union County Water**  
 Address: **500 N Main St**  
 City: **Montroe**  
 State, Zip: **NC, 28112**  
 Phone: **704-289-3307(Tra)**  
 Email: **Justin.Huntley@UnionCountyNC.gov**  
 Project Name: **PFAS - 533**  
 Site: **SSOW#**  
 Due Date Requested:   
 TAT Requested (days):   
 Compliance Project:  Yes  No  
 PO #:   
 Purchase Order not required:  Yes  No  
 Project #: **81004979**  
 SOW#:

Sample Identification	Sample Date	Sample Time	Sample Type (G=grab, G=grab)	Matrix (Water, Sewage, Other)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Analysis Requested	Total Number of containers	Special Instructions/Note:
<b>518 - Retobahn ARV</b>	<b>11/7/23</b>	<b>9:45 AM</b>	<b>G</b>	<b>Drinking Water</b>	<input checked="" type="checkbox"/> Yes	<input checked="" type="checkbox"/> Yes			
<b>707 - HWY 74 E BRB</b>	<b>11/7/23</b>	<b>10:00 AM</b>	<b>G</b>	<b>Drinking Water</b>	<input checked="" type="checkbox"/> Yes	<input checked="" type="checkbox"/> Yes			
<b>NOR - Newwood WTR</b>	<b>11/7/23</b>	<b>10:15 AM</b>	<b>G</b>	<b>Drinking Water</b>	<input checked="" type="checkbox"/> Yes	<input checked="" type="checkbox"/> Yes			

**Possible Hazard Identification**  
 Non-Hazard  Flammable  Skin Irritant  Poison B  Unknown  Radiological  
**Deliverable Requested:** I, II, III, IV, Other (specify)   
**Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)**  
 Return To Client  Disposal By Lab  Archive For **Months**

**Empty Kit Relinquished by:**  Date:   
**Relinquished by:** **Chris Tye** Date/Time: **11/08/23 12:09 PM** Company:   
**Relinquished by:** **Travis Phillips** Date/Time: **11/08/23 09:00** Company: **EEA**

**Custody Seal Intact:**  Yes  No **Custody Seal No.:**   
**Received by:** **Travis Phillips** Date/Time: **11/08/23 09:00** Company: **EEA**  
**Received by:**  Date/Time:  Company:   
**Cooler Temperature(s) °C and Other Remarks:**

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15

0.05 100 0.05  
0.05 100 0.05

0.05 100 0.05  
0.05 100 0.05  
0.05 100 0.05

0.05 100 0.05  
0.05 100 0.05  
0.05 100 0.05

0.05 100 0.05

0.05 100 0.05

## Login Sample Receipt Checklist

Client: Union County Water

Job Number: 810-84317-1

**Login Number: 84317**

**List Source: Eurofins Eaton Analytical South Bend**

**List Number: 1**

**Creator: Pehling-Wright, Penny**

Question	Answer	Comment
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	

